T. Venkata Rupa* et al.
(IJITR) INTERNATIONAL JOURNAL OF INNOVATIVE TECHNOLOGY AND RESEARCH
Volume No.5, Issue No.2, February – March 2017, 5791-5793.

# A Transient Solar Energy Utilizing System For Real Power Transmission On Clockwise

**T.VENAKATA RUPA**
M.Tech Student, Dept of EEE
Srinivasa Institute of Technology & Science,
Kadapa, A.P, India

**S.FAHMEEDA PARVEEN**
Assistant Professor, Dept of EEE\
Srinivasa Institute of Technology & Science,
Kadapa, A.P, India

*Abstract:* **This paper proposes novel current control, along with auxiliary damping control, for any grid-connected PV solar farm inverter to do something like a STATCOM both during day and night for growing transient stability and therefore the ability transmission limit. This power-flow level is selected is the base value by which the enhancements in power flow with various suggested controllers are compared. This research thus constitutes a strong situation to relax the current grid codes to permit selected inverter-based renewable generators (solar and wind) to workout damping control, therefore growing necessary power transmission capacity. The PV-STATCOM technology is going to be showcased the very first time inside a utility network of Ontario on the 10-kW PV solar system. The Ten-kW solar system will be part of current regulation and power factor correction additionally to generating real power. It is because real power generation boosts the PCC current which may be potentially useful in growing the ability transfer capacity. Within the PCC current control mode of operation, the PCC current is controlled through reactive power exchange between your DG inverter and also the grid. One SMIB system uses merely a single PV solar farm as PV-STATCOM connected in the midpoint whereas another system uses a mix of a PV-STATCOM and the other PV-STATCOM or perhaps an inverter-based wind distributed generator (DG) concentrating on the same STATCOM functionality. Maximum power point tracking (MPPT) formula according to an incremental conductance formula can be used to function the solar DGs at its maximum power point all the time and it is integrated using the inverter controller. The washout time constant is selected to permit the generator electromechanical oscillations within the frequency range as much as 2 Hz to feed.**

*Keywords:* **Inverter; Photovoltaic Solar Power Systems; Reactive Power Control; STATCOM; Transmission Capacity; Voltage Grid;**

## I. INTRODUCTION

During daytime, the inverter capacity left after real power production can be used to complete this objective. Initially, the bottom-situation generator operating electricity is chosen for performing the damping control design studies. This electricity is recognized as comparable to the transient stability limit from the system using the solar farm being disconnected during the night [1]. Transient stability research is conducted on the realistic single machine infinite bus power system getting a midpoint located PV-STATCOM using EMTDC/PSCAD simulation software. For PV-STATCOM operation during night time, the solar power panels are disconnected in the inverter and a tiny bit of real power is attracted in the grid to charge the electricity capacitor. The wind DG is modeled being an equivalent current-source inverter. The damping controller utilizes the entire rating from the DG inverter during the night to supply controlled reactive power and effectively damps the generator rotor-mode oscillations. The PV-STATCOM operation reveals a brand new chance for PV solar DGs to earn revenues within the night time and daytime additionally to that particular in the purchase of real power throughout the day. This can, obviously, require appropriate contracts between your regulators, network utilities, solar farm developers, and inverter manufacturers. Solar farms are idle during nights. A singular patent-pending control paradigm of PV solar farms is presented where they are able to operate throughout the night like a STATCOM with full inverter capacity and throughout the day with inverter capacity remaining after real power generation, for supplying significant enhancements within the power transfer limits of transmission systems. A 3-phase-to-ground fault of 5 cycles is used towards the generator bus at 8 s. The ability transfer limits acquired through transient stability studies for various cases. However, the goal of this paper is just to show a brand new idea of utilizing a PV solar farm inverter like a STATCOM with such reasonably good controller parameters. Within this controller, even though the line current magnitude signal can be used, other local or remote signals, which reflect the generator rotor-mode oscillations, can also be utilized. Within the solar DG, electricity power is supplied through the solar power panels, whereas within the full-ripper tools-based wind DG, electricity power arrives of the controlled ac-electricity rectifier attached to the PMSG wind generators, portrayed as "wind Turbine-Generator-Rectifier [2].

  



***Fig.1.Max Nightmare power transform***

## II. METHODOLOGY

The whole inverter rating from the PV solar farm, which remains dormant during night time, is required with current and damping controls to boost stable power transmission limits. Therefore, it might be difficult with limited reactive capacity to accomplish the right current profile at PCC for optimum power transfer and also to impart sufficient damping towards the oscillations. It's also noted by using lower accessibility to reactive power capacity after real power production, the opportunity to alter the bus current is restricted, which results in a lesser rise in power transmission capacity. The road for applying PV-STATCOM technology in large real-scale solar energy systems is a lot more complex than that for those 10-kW systems [3]. Major issues need to examined and addressed. The oscillations within the photovoltaic output during evening result from the active power exchanged through the solar inverter both throughout the charge and discharge cycles in attempting to conserve a constant current over the electricity-link capacitor, therefore enabling the inverter to function like a STATCOM. This is due to yet another constraint that although growing the ability transfer, the overshoot in PCC current shouldn't exceed 1.1 p.u. A larger increase is viewed during high-power generation by DG, since high output increases the PCC current profile that helps in growing the ability transfer capacity. The traditional reactive power control only regulates the reactive output from the inverter such that it may perform unity power factor operation together with electricity-link current control [4]. The utmost rise in the ability transfer limit during night time is achieved with a mix of current control and damping control, whereas exactly the same during daytime is accomplished with damping control alone. The potency of the suggested controls is shown on two study SMIB systems: System I has one 100-MW PV-STATCOM and System II has one 100-MW PV-STATCOM and the other 100-MW PV-STATCOM or 100-MW wind farm controlled as STATCOM. Three various kinds of STATCOM controls are suggested for that PV solar DG and inverter-based wind DG [5]. Both systems are single-machine infinite bus (SMIB) systems in which a large equivalent synchronous generator (1110 MVA) supplies capacity to the infinite bus more than a 200-km, 400-kV transmission line. The utmost stable generator power limit for that product is determined through transient stability studies for various modes of operation from the solar DG in study system 1, and individuals from the solar DG and also the solar/winds DGs in study system 2. The transfer function is composed of an increase, a washout stage, along with a first-order lead-lag compensator block. This controller is required to moist the rotor-mode oscillations from the synchronous generator and therefore improve system transient stability [6].

## III. CONCLUSION

The DG connected at bus 6 is really a PV-STATCOM and yet another DG at bus 5 will be an PV-STATCOM or perhaps a wind farm with STATCOM functionality. Within this situation, the wind farm employs permanent-magnet synchronous generator (PMSG)-based wind generator generators having a full ac-electricity-ac ripper tools. The suggested damping control around the two DGs (of rating 100 MW each) at night boosts the power transfer limits substantially by about 220 MW. This really is expected since at night, the whole inverter MVA rating of both DGs can be obtained for damping control. It's understood the solar DG and wind DG employ several inverters. A really little bit of negative power flow in the solar farm is noted during night time. The ability transfer capacity increase during the day is anticipated to become less than the night time, since only an element of the total inverter capacity can be obtained for damping control throughout the day. For that night time operation of solar DG, the electricity sources (solar arrays) are disconnected, and also the solar DG inverter is attached to the grid using appropriate controllers.

## IV. REFERENCES

[1] R. K. Varma, E. Siavashi, B. Das, and V. Sharma, “Novel application of a PV solar plant as STATCOM during night and day in a distribution utility network – Part 2,” presented at the IEEE Transm. Distrib. Conf., Orlando, FL, USA, May 2012.

[2] R. K. Varma, V. Khadkikar, and S. A. Rahman, “Utilization of distributed generator inverters as STATCOM,” Canada PCT Patent appl. PCT/CA2010/001419, Sep. 15, 2010.

[3] S.-K. Kim, J.-H. Jeon, C.-H. Cho, E.-S. Kim, and J.-B. Ahn, “Modeling and simulation of a grid-connected PV generation system for electromagnetic transient analysis,” Solar Energy, vol. 83, pp. 664–678, 2009.

  

[4] F. L. Albuquerque, A. J. Moraes, G. C. Guimaraes, S. M. R. Sanhueza, and A. R. Vaz, "Photovoltaic solar system connected to the electric power grid operating as active power generator and reactive power compensator," Solar Energy, vol. 84, no. 7, pp. 1310–1317, Jul. 2010.

[5] K. H. Hussein, I. Muta, T. Hoshino, and M. Osakada, "Maximum photovoltaic power tracking: an algorithm for rapidly changing atmospheric conditions," Proc. Inst. Elect. Eng., Gen., Transm. Distrib., vol. 142, no. 1, pp. 59–64, Jan. 1995.

[6] S. A. Rahman, R. K. Varma, and W. Litzenberger, "Bibliography of FACTS applications for grid integration of wind and PV solar power systems: 1995–2010, IEEE working group report," presented at the IEEE Power Energy Soc. Gen. Meeting, Detroit, MI, USA, Jul. 2011.

**AUTHOR's PROFILE**

T.Venakata Rupa has received the B.Tech (Electrical and Electronics Engineering) degree from Vignana Bharathi Institute of Technology & Science, Pallavolu in 2009 and Persuing M.Tech (Electrical Power Systems) in Srinivasa Institute of Technology & Science, Kadapa.

S.Fahmeeda Parveen has 3 years of experience in teaching in both Graduate and Post Graduate level and she is presently working as Assistant Professor in the department of EEE in SITS, Kadapa, AP, India.

  